




DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water Samples collected from "New Delhi Public School", A- Block, Vikaspuri, New Delhi -110018 Vide Challan No. 145 Dt-09.09.2024.


S1: DJB Supply at above site


**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.**


S2: Drinking Point at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	19-09-2024	19-09-2024
2.	Date of Analysis	-----	--	--	25-09-2024	25-09-2024
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.4	1.2
6.	PH value	-----	6.5	8.5	7.5	7.5
7.	Electrical Conductivity	µmho/cm	--	--	238.9	249.5
8.	Total dissolved solids	mg/l	500	2000	155.3	162.2
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	Nil
10.	Total Alkalinity	mg/l	200	600	72	74
11.	Total Hardness	mg/l	200	600	96	98
12.	Calcium Hardness	mg/l	--	--	68	68
13.	Magnesium Hardness	mg/l	--	--	28	30
14.	Calcium as Ca	mg/l	75	200	27.2	27.2
15.	Magnesium as Mg	mg/l	30	100	6.72	7.20
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	-	-
19.	Sulphate	mg/l	200	400	22	20
20.	Chloride	mg/l	250	1000	18	18
21.	Dissolved Iron	mg/l	1	N.R.	0.06	0.04
22.	Fluoride	mg/l	1	1.5	0.20	0.18
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.40	0.30
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0	0
REMARKS: As per tested parameters Sample S1 is found to be fit for consumption.						

REMARKS: As per tested parameters Sample S1 and S2 can be used for drinking purpose.


ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41


BACT.


A/CHEMIST



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2025/D- 2195

Dated: 21/01/25


HEALTH CERTIFICATE

1. Name of the School New Delhi Public School
2. School address A-Block, Vikas Puri New Delhi-110018
3. No of shifts 01 (Morning) Timing 08.00 AM TO 03.00 PM
4. No of students:- Boys 881 Girls 408 Total 1289
5. No of staff:- Gents 08 Ladies 42 Total 50

Accommodation provide for classroom as under:-

Floor area in the classroom is sufficient /insufficient Sufficient
Classes are well lighted/ ill lighted Well lighted
Classrooms are well ventilated/ill ventilated Well ventilated
Classes are kept/ not kept neat and clean Neat & clean
Building/ classrooms require/ do not require white wash etc. not required
Drinking water is wholesome/ not wholesome wholesome
Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue


Dy. Health Officer
West Zone

Dr. NAGESHWAR MARANDI
Dy. Health Officer
(West Zone) MCD